


Reaction to fire



The applicant: **PIERRE FREY SAS**
47 RUE DES PETITS-CHAMPS
FR-75001 PARIS

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2021AN2094



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

N° 21AN2094

The range:

“EW”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

“B-s2,d0”

Alcoy, November 09th 2018.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.